



## CLEARANCE STATEMENT

CLIENT: El Paso Independent School District

PROJECT NAME: Austin High School

LOCATION: 2<sup>nd</sup> floor West / First Containment.

DATE: February 28, 2019

This Environmental Statement is to certify that 2<sup>nd</sup> floor west area located at Austin High School in El Paso, Texas was under an asbestos abatement project. The purpose of this project was the removal of Asbestos Containing floor tile, floor tile mastic, transite chalkboards and laboratory transite table tops. A Negative Pressure Enclosure (NPE) was built at above mentioned area. Asbestos abatement was performed in accordance with all applicable Federal and State Regulations and following the Technical Specifications for this specific Project. The Asbestos Abatement Contractor involved in this Project was Border Demolition and Environmental.

The final visual inspection was performed by the Project Manager delegated by the Asbestos Consultant.

Clearance air sampling was conducted, using aggressive methods, after a final visual inspection and results were <0.005 f/cc for all clearance samples, which are below the EPA's clearance level of 0.01 f/cc. This area therefore can be re-occupied.

Asbestos Project Manager: \_\_\_\_\_  
Oscar E. Ayala

Asbestos Consultant: \_\_\_\_\_  
Juan R. Ayala