



CLEARANCE STATEMENT

CLIENT: El Paso Independent School District

PROJECT NAME: Coronado High School


LOCATION: Building B


DATE: February 22, 2019

This Environmental Statement is to certify that Building "B" located at Coronado High School in El Paso, Texas was under an asbestos abatement project. The purpose of this project was the removal of Asbestos Containing exterior transite panels. Asbestos abatement was performed in accordance with all applicable Federal and State Regulations and following the Technical Specifications for this specific Project. The Asbestos Abatement Contractor involved in this Project was Border Demolition and Environmental.

The final visual inspection was performed by the Project Manager delegated by the Asbestos Consultant.

PCM Clearance air sampling was conducted, using aggressive methods, after a final visual inspection and results were <0.005 f/cc for all clearance samples, which are below the EPA's clearance level of 0.01 f/cc. This area therefore can be re-occupied.

Asbestos Project Manager:  _____
Oscar E. Ayala

Asbestos Consultant:  _____
Juan R. Ayala