



CLEARANCE STATEMENT

CLIENT: El Paso Independent School District

PROJECT NAME: Crockett Elementary School

LOCATION: Room 105 and 2nd Floor


DATE: July 25, 2018

This Environmental Statement is to certify that all second floor and room 105 located at Crockett Elementary School in El Paso, Texas were under an asbestos abatement project. The purpose of this project was the removal of Asbestos Containing floor tile, floor tile mastic, transite chalkboards, A Negative Pressure Enclosure (NPE) was built at above mentioned area. Asbestos abatement was performed in accordance with all applicable Federal and State Regulations and following the Technical Specifications for this specific Project. The Asbestos Abatement Contractor involved in this Project was Border Demolition and Environmental.

The final visual inspection was performed by the Project Manager delegated by the Asbestos Consultant.

TEM Clearance air sampling was conducted, using aggressive methods, after a final visual inspection and results for all clearance samples were below the EPA's clearance levels. This area therefore can be re-occupied.

Asbestos Project Manager: _____


Oscar E. Ayala

Asbestos Consultant: _____


Juan R. Ayala